



Italia

Scegli la certezza.  
Aggiungi valore.

## FIRE SAFE TEST CERTIFICATE

CERTIFICATE NUMBER: **FS-941-722203860**

CLIENT: **EMMECI GRV FLOW CONTROLS S.r.l.**  
ADDRESS: **Via Verta, 49  
Omegna (VB) - Italy**

REPORT NUMBER: **FTR 84-2019**

SCOPE OF REPORT: Fire Safe test carried out according to:  
API 6FA 3<sup>rd</sup> Edition (R2011)  
API 607 7<sup>th</sup> Edition - ISO 10497:2010  
Operative instruction No. IO 8.5\_04 Rev. 0

QUALIFIED VALVE

|                       |                                    |
|-----------------------|------------------------------------|
| Size:                 | <b>12"</b>                         |
| Rating Class:         | <b>150 LBS</b>                     |
| Drawing N°:           | <b>FT84-19</b>                     |
| Type/Model:           | <b>Butterfly valve</b>             |
| Valve Material:       | <b>ASTM A216 WCB</b>               |
| Seat Insert Material: | <b>SS316</b>                       |
| Gasket Material:      | <b>SS316 + GRAPHITE</b>            |
| Bolting Material:     | <b>ASTM A193 B7 / ASTM A194 2H</b> |

For further details of test arrangements and test results, please see Fire Test Report No. FTR 84-2019 herewith attached and duly endorsed.

RANGE AND TYPE OF VALVES COVERED (API 6FA):

**For API 6D**  
**Size 12" and larger**  
**Class 150 and 300**

**For API 6A**  
**N/A**

RANGE AND TYPE OF VALVES COVERED (API 607):

**For API 6D**  
**Size 12" and larger**  
**Class 150 and 300**



CERTIFICATION DATE

02/08/2019

MANAGEMENT OF INSPECTION SERVICE

F. LOCATELLI

